

[REDACTED] P.E.  
ENGINEERING & CONSTRUCTION CONSULTANT  
[REDACTED]  
[REDACTED]

August 4, 2007

[REDACTED]  
[REDACTED]  
[REDACTED]

Re: Engineer's Certification/Recommendation-Existing foundation for second floor addition

Address: [REDACTED]

Mr. [REDACTED]

At your request, I inspected the foundation at the above referenced location and find that the basement foundation walls should be replaced with new foundation walls and footings. The existing crawl space has proper depth and foundation walls for the proposed addition. The new walls should be minimum 8 inches thick. I [REDACTED] certify this foundation as recommended. [REDACTED] but if there are any questions on this [REDACTED] please contact my office.

Sincerely,  
[REDACTED]



**Foundation Certification**