

SIGNAGE

EXTERIOR – Connections shall be identified in accordance with NFPA 170, Standard for Fire Safety Symbols and be readily visible by approaching fire apparatus.

Examples below:

Signs for fire department sprinkler/standpipe connection. NFPA 1, as amended by the Anne Arundel County Fire Prevention Code. Symbols for use by the fire service shall be on a **minimum 18" x 18"** square, reflective sign, unless otherwise approved.

Single Connection. (5" Stortz or any single connection)



Sprinkler Only



Sprinkler & Standpipe



Standpipe Only

Siamese Connection (2 1/2" Siamese)



Sprinkler Only



Sprinkler & Standpipe



Standpipe Only

Fire Alarm Control Panel and Sprinkler Rooms



Fire Alarm Control Panel



Sprinkler Room

SIGNAGE

INTERIOR - Interior Signs shall have minimum 1” lettering.



Fire Alarm Control Panel



Sprinkler Room



Electrical Room



Gas Shutoff Valve

Interior doors not in a stairwell shall identify roof access.



Roof Access



Roof Access

SIGNAGE

Stairwell Signs

NFPA 101: Life Safety Code - Chapter 7 Means of Egress

7.2.2.5.4 * Stairway Identification.

7.2.2.5.4.1

New enclosed stairs serving three or more stories and existing enclosed stairs, other than those addressed in 7.2.2.5.4.1(P), serving five or more stories shall comply with 7.2.2.5.4.1(A) through 7.2.2.5.4.1(O).

